



Product Service

CERTIFICATE

No. Z2 087629 0013 Rev. 00

Holder of Certificate: CATERPILLAR INC.
100 North East Adams Street
Peoria IL 61629
USA

Certification Mark:



Product: Crystalline Silicon Terrestrial Photovoltaic (PV) Modules
Mono-crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 701262002401-00

Valid until: 2024-12-04

Date, 2020-03-18 (Zhulin Zhang)

ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT



Product Service

CERTIFICATE

No. Z2 087629 0013 Rev. 00

Model(s):

PVCxxxMP03H (xxx=365-405, in step of 5)
PVCxxxMP03H (xxx=420-460, in step of 5)
xxx is standing for rated output power at STC.

Parameters:

Severity of	
Salt Mist Test:	Severity 6 and severity 1
Application Class:	Class A
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class C
Construction:	Framed, with Junction box, Cable and Connectors.

Tested according to:

IEC 61215:2005
IEC 61730-1:2004
IEC 61730-1:2004/AMD1:2011
IEC 61730-1:2004/AMD2:2013
IEC 61730-2:2004
IEC 61730-2:2004/AMD1:2011
IEC 61701:2011

Production Facility(ies):

096558, 002875, 001192, 090968, 099626, 099605, 099606,
097323, 102892, 103410, 103841

ZERTIFIKAT ◆ CERTIFICATE ◆ 認證書 ◆ CERTIFICADO ◆ CERTIFICAT